

Diagram illustrating the wire stop assembly. The assembly consists of a cylindrical component with a beveled entry at both ends. The component is labeled with "SCL 300" and "300 MCM". The ends are labeled "DIE P66". A wire is inserted into the center, with a "WIRE STOP" at the end. The outer diameter is labeled "O.D." and the inner diameter is labeled "I.D.". A dimension line "A" indicates the length of the central section.

NOTES:

1. MATERIAL - HIGH CONDUCTIVITY SEAMLESS COPPER TUBING.
2. ELECTRO-TIN PLATED.
3. BARREL COLOR CODED WITH DIE SET INDEX NUMBER.
4. UL LISTED WITH CODE COPPER CONDUCTORS FOR APPLICATIONS UP TO 35 KV, FILE E52164.
5. CONSULT CABLE MANUFACTURER FOR VOLTAGE STRESS RELIEF INSTRUCTIONS WITH APPLICATIONS GREATER THAN 2000 VOLTS.
6. CSA CERTIFIED FOR APPLICATIONS UP TO 600 V, FILE LR31212.
7. FOR USE WITH COPPER CABLES ONLY.

 **LISTED**
587H
E52164

 **CERTIFIED**
LR31212

									PANDUIT CORP	TINLEY PARK, ILLINOIS
									SCL STANDARD BARREL #300 THRU 1000 COPPER SPLICES	
03	4/01	BDK		ADDED THE LETTER "PP" TO THE DTE INDEX NUMBER, ADDED CY-9860-CY-9860, CY-9860 & CY-9800A. DRAWING NUMBER WAS INATTENTIONAL OF REMOVED ALTERNATE DTE INDEX NUMBER NOTE, REVISED UL/CSA LOGOS, ADDED EXPANDED WIRE RANGE					UNLESS OTHERWISE SPECIFIED, TOLERANCES ARE: (.XX) ± (.XXX) ± ANGLES ±	UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE GIVEN IN INCHES, THIRD ANGLE PROJECTION.
02	3.94	WB		ADDITIONAL NOTES ADDED.		K\$				
01	11-93	PWS		FILESPEC WAS C41106 & DWG WAS C41106	01884	RM	LA	DRAWN BY PWS	MAT'L E SEE NOTEST ABOVE	SCALE N/A
00	3-93	PWS	GRAM	RELEASED	01415			DATE 3-10-93		DRAWING NO. C41132 DES BUL
REV	DATE	BY	CHK	DESCRIPTION	ECN	PM	CUST	DWG GRAM		

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Panduit:

[SCL500-6](#) [SCL750-6](#) [SCL1000-3](#) [SCL300-X](#)