

RESISTANCE @  $+25^{\circ}C = 2,252 \Omega$  NOMINAL ACCURACY (0 TO  $+70^{\circ}C$ ) =  $\pm$  0.10°C RESISTANCE/TEMPERATURE CURVE = "J" BETA " $\beta$ " (0 TO  $+50^{\circ}C$ ) = 3,892°K NOMINAL TEMPERATURE COEFFICIENT @  $+25^{\circ}C = -4.4\%$ /°C NOMINAL MAXIMUM TEMPERATURE RATING =  $+105^{\circ}C$ 

MAXIMUM TEMPERATURE FOR BEST LONG TERM STABILITY = +75°C

\*\*\* ROHS COMPLIANT

SEE MANUFACTURING SPECIFICATION (LAYER 1)

NONE	RELEASE TO PRODUCTION	09/30/10	DD
REV	REVISION RECORD	DATE	APP

scale NONE	C COPYRIGHT	
DRAWN BY  DAN DANKERT	U.S. SENSOR CORP	
DATE 09/30/10	714-639-1000 www.ussensor.com NTC THERMISTOR PROBE	
REV. NONE	P/N USP11493	
EMIER O OI E		